State of California—Health and Human Services Agency
California Department of Public Health
DRINKING WATER FIELD OPERATIONS BRANCH
50 D STREET, SUITE 200, SANTA ROSA, CA 95404
PHONE: (707) 576-2145 / FAX: (707) 576-2722
INTERNET ADDRESS: www.cdph.ca.gov

Ron Chapman, MD, MPH
Director & State Health Officer

EDMUND G. BROWN JR.
Governor

RECEIVED
JUL 26 2012
SWEETWATER SPRINGS
WATER DISTRICT

July 25, 2012

Water System No. 4910004

Stephen Mack
Sweetwater Springs Community Water District – Guerneville
P.O. Box 48
Guerneville, CA 95446

2012 ANNUAL INSPECTION

Dear Mr. Mack:

The purpose of this letter is to provide you the results of the California Department of Public Health (Department) inspection of the Sweetwater Springs Community Water District – Guerneville (System) water system. The treatment, sources, and storage facilities were inspected in June 2012.

The System was found in good overall condition and is under competent management. The purpose of this letter is to inform you of the findings of our inspection and assist the System to be in full compliance with applicable sections of the California Health and Safety Code (CHSC) and the California Code of Regulations (CCR). We appreciate the assistance of Kevin Gilman, Jack Bushgen, and you in the completion of this inspection.

Well Investigation
System staff expeditiously corrected sanitary deficiencies (threaded hose bibs) identified during the inspection from El Bonita Well 04, 05, and 06.

Tank Housekeeping
While most tanks and tank sites were found to be very clean, the Canyon 6 tank was found to be dirty; it was covered with spider webs and various yard waste debris. This deficiency was addressed quickly and the site and tank exterior has been cleaned. The System should routinely monitor tank exteriors to keep them clean.

Valve Exercising Program
The System should implement a formal valve exercising program by the end of 2012.

Leaky Tanks
The Lower Summit, Drake, and Natoma tanks were found to be leaking slightly. These tanks should be either repaired, lined, or replaced.

New Permit

Enclosed is a new Water Supply Permit for your System. Please read over the permit provisions carefully as they describe the conditions under which the water system must be operated. Pursuant to Section 116550(a) of the CHSC, the System may not change its sources or treatment without a valid permit being issued by the Department prior to modification.

Please acknowledge receipt of this permit by sending a letter to this Department stating that it has been accepted by **August 17, 2012**.

We appreciate the System's efforts to operate the water system in compliance with all applicable laws and regulations contained in the California Health and Safety Code and the California Code of Regulations and produce high quality potable water for its customers.

Please respond in writing by **August 17, 2012**, indicating receipt of this letter. Please also inform the Department if there are any inaccuracies in the inspection report or permit.

If you have any questions about this letter, please contact Waldon Wong at (707) 576-2764.

Sincerely,

Janice M. Thomas, P.E.
Sonoma District Engineer
Drinking Water Field Operations Branch

Enclosure: 2012 Annual Inspection Report
Domestic Water Supply Permit 02-18-12P-4910004